

# ZONELINE TRANSITION: ELECTRICAL CONNECTION

**230/208V**

Outlet



RAK3153A → RAK315P  
 RAK3203A → RAK320P  
 RAK3303A → RAK330P

OR

Direct



RAK4157 → RAK315D  
 RAK4207 → RAK320D  
 RAK4307 → RAK330D

OR

Subbase



Existing Subbase



RAK204D15P → RAK204D15PA  
 RAK204D20P → RAK204D20PA  
 RAK204D30P → RAK204D30PA

Powercord included

AND



Short Power Cords  
 RAK315SP  
 RAK320SP  
 RAK330SP

**265V**

Direct



RAK5157 → RAK515D  
 RAK5207 → RAK520D  
 RAK5307 → RAK530D

OR

Subbase



RAK204E15  
 RAK204E20  
 RAK204E30



For 265V always order power cord with subbase

AND

RAK5172 → RAK515P  
 RAK5202 → RAK520P  
 RAK5302 → RAK530P

**New Zonline units AZ45/65 require new power cords. Old cords are not compatible with AZ45/65 models.**

